



Certificate of Compliance

This certificate is issued for the following:

Angle Hose Valves

Models FM104G, FM104S1, and FM104S4
(refer to attached table)

Prepared for:

Shah Bhogilal Jethalal & Bros
Gheekanta Road
Nr Madhuram Cinema
Ahmedabad, 380 001
India

Manufactured at:

Shah Bhogilal Jethalal & Bros
Gheekanta Road
Nr Madhuram Cinema
Ahmedabad, 380 001
India

FM Approvals Class: 1521

Approval Identification: 0003040344

Approval Granted: September 15, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry
to reduce property losses.*

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Model	Product Description	Maximum Working Pressure, psi (kPa)	Nominal Pipe Size, in.	Remarks
FM104G	Flange x BS 336 Instantaneous Female Connection	175 (1205)	2-1/2	a
FM104S1	Flange x BS 336 Instantaneous Female Connection	175 (1205)	2-1/2	a
FM104S4	Flange x BS 336 Instantaneous Female Connection	175 (1205)	2-1/2	a

Note:

- a. Inlet flange may be drilled to accommodate: 3 inch ASME/ANSI B16.5, or DN80 IS: 1538 (Part IV) pattern mating flanges.



Member of the FM Global Group