



## GFXX.EX6995 Foam Monitors

[Page Bottom](#)

### Foam Monitors

[See General Information for Foam Monitors](#)

**SHAH BHOGILAL JETHALAL & BROS**

EX6995

NR MADHURAM CINEMA  
GHEEKANTA RD  
AHMEDABAD, GJ 380001 INDIA

Foam Monitors with specified nozzles for application of foam solutions. The following are discharge rates for the monitor inlet pressures:

Monitor Model	Nozzle Model	Type	Monitor Inlet Pressure, psi	Solution Discharge Flow Rate, gpm
AAAG FM 500	500 GPM	Self Inducting	100	500
AAAG FM 675	675 GPM	Self Inducting	100	675
AAAG FM 750	750 GPM	Self Inducting	100	730
AAAG FM 1000	1000 GPM	Self Inducting	100	975
AAAG FM 2000	2000 GPM	Self Inducting	100	2000
AAAG FM 750	750 GPM	for use with Model AAAG 750 JRC	100	750
AAAG FM 1000	1000 GPM	for use with Model AAAG 1000 JRC	100	1000
AAAG FM 2000	2000 GPM	for use with Model AAAG 2000 JRC	100	2000
AAAG FMV 500- 750	500-750 GPM at 500	Self Inducting	100	500
AAAG FMV 500- 750	500-750 GPM at 750	Self Inducting	100	750
AAAG FMV 500-750-1000	500-750-1000 GPM at 500	Self Inducting	100	500
AAAG FMV 500-750-1000	500-750-1000 GPM at 750	Self Inducting	100	750
AAAG FMV 500-750-1000	500-750-1000 GPM at 1000	Self Inducting	100	1000
AAAG FMV 500-750-1000	500-750-1000 GPM at 500	For use with Model AAAG JRC 500	100	500
AAAG FMV 500-750-1000	500-750-1000 GPM at 750	For use with Model AAAG JRC 750	100	750
AAAG FMV 500-750-1000	500-750-1000 GPM at 1000	For use with Model AAAG JRC 1000	100	1000
AAAG FMV 500-750-1000	500-750-1000 GPM at 500	For use with Model AAAG SINGLE JRC 500-750-1000	100	500
AAAG FMV 500-750-1000	500-750-1000 GPM at 750	For use with Model AAAG SINGLE JRC 500-750-1000	100	750
AAAG FMV 500-750-1000	500-750-1000 GPM at 1000	For use with Model AAAG SINGLE JRC 500-750-1000	100	1000
AAAG FMV 1000-	1000-1500-2000 GPM	Self Inducting	100	1000

1500-2000	at 1000			
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 1500	Self Inducting	100	1500
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 2000	Self Inducting	100	2000
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 1000	For use with Model AAAG JRC VF 1000	100	1000
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 1500	For use with Model AAAG JRC VF 1500	100	1500
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 2000	For use with Model AAAG JRC VF 2000	100	2000
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 1000	For use with Model AAAG SINGLE JRC 1000-1500-2000	100	1000
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 1500	For use with Model AAAG SINGLE JRC 1000-1500-2000	100	1500
AAAG FMV 1000-1500-2000	1000-1500-2000 GPM at 2000	For use with Model AAAG SINGLE JRC 1000-1500-2000	100	2000

Refer to the individual foam concentrate Listings for operating limitations with specific combinations of foam concentrates and monitors.

Last Updated on 2012-10-05

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".